

Building Type	County	
EOC-Confidential Location		
Street		
City	State	Zip
	OR	
Latitude	Longitude	
Tracking Code	Inspection Date	
RVS in 2006	8/2/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	0	0	0	0	0	0	1.8
Secondary	C2	2.8	-1	0	0	0	0	0	0	1.8
Tertiary	S1	2.8	-1	0	0	0	0	0	0	1.8

Hood River EOC/911

Final RVS Score

Final Type      Final Score

RM1

1.8

FEMA-154 Collapse Potential

Moderate (>1%)

**No  
Planview  
Available**

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: U shaped	Building On Hill or Sloped Site
None	Steps in Elevation View: Single Change
None	None

Falling Hazards	Poor Conditions
Other: Brick Veneer	None
Other: Light Cladding	None
Parapets: General	None



W Elevation View



W Elevation View



W General Site



S General Site



S Elevation View



E Elevation View