

Morrow County

Building Type	County	
EOC-Confidential Location - Co		
Street		
City	State	Zip
	OR	
Latitude	Longitude	
Tracking Code	Inspection Date	
RVS in 2006	7/25/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	0	0	1.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Morrow County Emergency Operations Center

Final RVS Score

Final Type Final Score

RM1

1.1

FEMA-154 Collapse Potential

Moderate (>1%)

**No
Planview
Available**

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners:Other (Adjacent Build/Entity)	Steps in Elevation View: Single Change (Adjacent Building/Entity)
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



S Primary Structural Type



S Building Name



N Elevation View

Morrow County

Building Type	County	
EOC-Confidential Location - Co		
Street		
City	State	Zip
	OR	
Latitude	Longitude	
Tracking Code	Inspection Date	
RVS in 2006	7/25/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	0	0	1.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Morrow County Emergency Operations Center

Final RVS Score

Final Type Final Score

RM1

1.1

FEMA-154 Collapse Potential

Moderate (>1%)

**No
Planview
Available**

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners:Other (Adjacent Build/Entity)	Steps in Elevation View: Single Change (Adjacent Building/Entity)
None	Building On Hill or Sloped Site
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



S Vertical Irregularity Primary