

# North Baker Elementary School

Bake\_sch01A

Baker SD 5J

Building Type	County	
School	Baker	
Street		
2725 Seventh St		
City	State	Zip
Baker City	OR	97814
Latitude		Longitude
44.78399		117.83829
Tracking Code		Inspection Date
RVS in 2006		8/11/2006



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	3.4	-1.5	-0.5	-0.4	0	0	-0.8	0	0.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

North Baker Elementary School

## Final RVS Score

Final Type      Final Score

URM

0.2

FEMA-154 Collapse Potential


High (>10%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
298		1913	1910
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
36302	2	Yes	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners:Other (Adjacent Build/Entity)	Steps in Elevation View: Single Change (Adjacent Building/Entity)
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



Baker SD 5J

Building Type	County	
School	Baker	
Street		
2725 Seventh St		
City	State	Zip
Baker City	OR	97814
Latitude	Longitude	
44.78417	117.83805	
Tracking Code	Inspection Date	
RVS in 2006	8/11/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

North Baker Elementary School

Final RVS Score

Final Type      Final Score

RM1

-0.1

FEMA-154 Collapse Potential

Very High (100%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
298		1913	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
36302	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other (Adjacent Build/Entity)	Steps in Elevation View: 2 to 3 Changes
Reentrant Corners: Other	Steps in Elevation View: Single Change (Adjacent Building/Entity)
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



E Primary Structural Type



N Elevation View



N Vertical Irregularity Primary



NW Elevation View



SW Plan Irregularity Secondary