

Colton SD 53

Building Type	County	
School	Clackamas	
Street		
30439 S Grays Hill Rd		
City	State	Zip
Colton	OR	97017
Latitude		Longitude
45.16582		122.41725
Tracking Code		Inspection Date
Hasenberg 02		9/15/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	0	0	0	-0.8	0	0	4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Colton Elementary School

Final RVS Score

Final Type      Final Score

W2

4

FEMA-154 Collapse Potential

Low (<1%)

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
310		1975	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
51085	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions

