



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
542		1964	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
77099	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: L Shaped	Steps in Elevation View: 2 to 3 Changes
None	Short Columns
None	None

Falling Hazards	Poor Conditions
Other: Ornamental Hazard Over Exit	None
None	None
None	None



NW Plan Irregularity Primary



SW Elevation View



SW Vertical Irregularity Primary



N Elevation View



NW Elevation View



W Secondary Structural Type  
wood/c2 transition



N Secondary Structural Type  
solid jts



N Vertical Irregularity Secondary  
@ windows in gym



NE Elevation View



NW General Site  
sea of modulares



E Secondary Structural Type  
wood/c2 transition



E Elevation View



SE Secondary Structural Type  
c2 boiler rm