

Charleston RFPD

Building Type	County	
Fire - RFPD	Coos	
Street		
92342 Cape Arago Hwy		
City	State	Zip
Coos Bay	OR	97420
Latitude		Longitude
43.37096		124.29186
Tracking Code		Inspection Date
RVS in 2006		8/18/2006



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary	W2	3.8	-2	-0.5	0	2.4	-0.4	0	0	3.3
Tertiary		0	0	0	0	0	0	0	0	0

Charleston RFPD

Final RVS Score

Final Type      Final Score

RM1

0.9

FEMA-154 Collapse Potential

High (>10%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other (Adjacent Build/Entity)	Steps in Elevation View: Single Change (Adjacent Building/Entity)
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



SE General Site



E Vertical Irregularity Primary