

East Sutherlin Primary School

Doug_sch27A

Sutherlin SD 130

Building Type	County	
School	Douglas	
Street		
323 E Third Ave		
City	State	Zip
Sutherlin	OR	97479
Latitude		Longitude
43.39344		123.3108
Tracking Code		Inspection Date
RVS in 2006		8/11/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	0	0	0	0	0	0	0	2.8
Secondary	W2	3.8	0	0	0	0	0	0	0	3.8
Tertiary		0	0	0	0	0	0	0	0	0

East Sutherlin Primary School

Final RVS Score

Final Type Final Score

C2

2.8

FEMA-154 Collapse Potential

Low (<1%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
422		1944	1940
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
49500	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other (Adjacent Build/Entity)	Steps in Elevation View: Single Change (Adjacent Building/Entity)
Reentrant Corners: Other	Building On Hill or Sloped Site
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



S Primary Structural Type



W Vertical Irregularity Secondary



W Plan Irregularity Secondary and secondary LFRS.



S Pounding Potential
5" joint between buildings



S General Site
2000 addition.