

Blue Mountain Hospital - John Day

Gran_hos01A

NFP (BM Hospital District)

| | | |
|---------------|-----------------|-------|
| Building Type | County | |
| Hospital | Grant | |
| Street | | |
| 170 Ford Rd | | |
| City | State | Zip |
| John Day | OR | 97845 |
| Latitude | Longitude | |
| 44.41699 | 118.95971 | |
| Tracking Code | Inspection Date | |
| New Building | 7/27/2006 | |



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

| | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary | RM1 | 3.6 | -2 | -0.5 | 0 | 0 | -0.8 | 0 | 0 | 0.3 |
| Secondary | C2 | 3.6 | -2 | -0.5 | 0 | 0 | -0.8 | 0 | 0 | 0.3 |
| Tertiary | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Blue Mountain Hospital - John Day

Final RVS Score

Final Type

Final Score

RM1

0.3

FEMA-154 Collapse Potential

Low (<1%)



| | | | |
|------------------------|-----------------------------|--------------------------|--------------------|
| Enrollment | Year Built (Field Verified) | Year Built (Alt. Source) | Est. Decade Built |
| | | 2003 | 1960 |
| Total Area (square ft) | Number of Stories | Basement | Pounding Potential |
| | 1 | No | No |

| | |
|--------------------------|--|
| Plan Irregularities | Vertical Irregularities |
| Reentrant Corners: Other | Steps in Elevation View: Single Change |
| None | None |
| None | None |

| | |
|-----------------|-----------------|
| Falling Hazards | Poor Conditions |
| None | None |
| None | None |
| None | None |



E Elevation View