


Lake County

Building Type	County	
Police - County	Lake	
Street		
513 Center Street		
City	State	Zip
Lakeview	OR	97630
Latitude		Longitude
42.18895		120.34526
Tracking Code		Inspection Date
RVS in 2006		6/28/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Tertiary	C1	3	-2	-0.5	0	0	0	-1	0	-0.5

Lake County Sheriff Department

Final RVS Score

Final Type Final Score

C1

-0.5

FEMA-154 Collapse Potential

Very High (100%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1953	1953	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	Yes	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: L Shaped	Steps in Elevation View: 2 to 3 Changes
None	None
None	None

Falling Hazards	Poor Conditions
Other: General	Cracks
Other: Brick Veneer	None
None	None



E Primary Structural Type



N General Site



N Elevation View



W Seismic Upgrade



W Falling Hazard



S Other



S Building Quality



S Building Quality



S Primary Structural Type