

Lane CC

Building Type		County	
Community_College		Lane	
Street			
4000 E 30th Ave			
City		State	Zip
Eugene		OR	97405
Latitude		Longitude	
44.00946		123.03125	
Tracking Code		Inspection Date	
Miller 2004-05		8/17/2005	

Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC2	2.4	-1	-0.5	0	0	0	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Machine Technology

Final RVS Score

Final Type


Final Score

PC2

0.9

FEMA-154 Collapse Potential

High (>10%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1970	1970	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
59658	2	No	No

Plan Irregularities	Vertical Irregularities
None	Yes: Unknown

Falling Hazards	Poor Conditions
None	
None	
None	