

Building Type	County	
Fire - RFPD	Lane	
Street		
37818 Camp Creek Rd		
City	State	Zip
Springfield	OR	97478
Latitude	Longitude	
44.06762	122.86781	
Tracking Code	Inspection Date	
New Building	7/20/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	-0.5	0	1.6	0	-1.2	0	4.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mckenzie Fire & Rescue

Final RVS Score

Final Type Final Score

W2

4.7

FEMA-154 Collapse Potential

Low (<1%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			2000
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
Torsion: Eccentric Stiffness	None
Reentrant Corners: L Shaped	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



S Plan Irregularity Secondary



E Primary Structural Type



E Plan Irregularity Primary