

Eugene Fire Station 03 University

Lane_fir44A

City of Eugene

Building Type	County	
Fire - City	Lane	
Street		
1695 Agate St		
City	State	Zip
Eugene	OR	97403
Latitude	Longitude	
44.04129	123.06919	
Tracking Code	Inspection Date	
Structural Engineering Report	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	0	0	0	0	0	0	0	4.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Eugene Fire Station 03 University

Final RVS Score

Final Type

Final Score

W1

4.4

FEMA-154 Collapse Potential

Low (<1%)

No Planview Available

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1949	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
5000	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions