

# Eugene Fire Station 10 Bailey Hill

Lane\_fir74A

City of Eugene

Building Type	County	
Fire - City	Lane	
Street		
2002 Bailey Hill Road		
City	State	Zip
Eugene	OR	97402
Latitude	Longitude	
44.03805	123.15079	
Tracking Code	Inspection Date	
Structural Engineering Report	9/15/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	0	0	2.4	0	0	0	6.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Eugene Fire Station 10 Bailey Hill

## Final RVS Score

Final Type

Final Score

W2

6.2

FEMA-154 Collapse Potential

Low (<1%)

# No Planview Available

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1981	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
5400	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions