

Building Type	County	
School	Lane	
Street		
1401 Laurel St		
City	State	Zip
Junction City	OR	97448
Latitude	Longitude	
44.22586	123.20883	
Tracking Code	Inspection Date	
RVS in 2006	1/30/2007	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Laurel Elementary School

Final RVS Score

Final Type Final Score

W2

0.5

FEMA-154 Collapse Potential

High (>10%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
558		1949	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
53102	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: Very Irregular Changes
None	None
None	None

Falling Hazards	Poor Conditions
Unreinforced Chimneys	None
Other: Brick Veneer	None
Other: Ornamental Hazard Over Exit	None



E Vertical Irregularity Primary



E Elevation View



E Elevation View



NE General Site
1995 kgarten



SW Falling Hazard



SE Vertical Irregularity Primary



NW General Site
1995 kgarten



W Falling Hazard