

Building Type	County	
School	Linn	
Street		
3610 Oak St SE		
City	State	Zip
Albany	OR	97322
Latitude		Longitude
44.60807		123.08595
Tracking Code		Inspection Date
Hasenberg 02		9/15/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	0	0	0	0	-0.8	0	3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Oak Elementary School

Final RVS Score

Final Type Final Score

W2

3

FEMA-154 Collapse Potential

Low (<1%)

**No
Planview
Available**

Enrollment 290	Year Built (Field Verified)	Year Built (Alt. Source) 1971	Est. Decade Built
Total Area (square ft) 42240	Number of Stories 1	Basement No	Pounding Potential No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions



S General Site



S General Site