

Treasure Valley CC

Building Type	County	
Community_College	Malheur	
Street		
650 College Blvd		
City	State	Zip
Ontario	OR	97914
Latitude		Longitude
44.01873		116.97273
Tracking Code		Inspection Date
Miller 2004-05		8/11/2005

Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC2	3.2	-1.5	-0.5	0	0	0	-1.2	0	0
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Oregon Trail Building

Final RVS Score

Final Type

Final Score

PC2

0

FEMA-154 Collapse Potential

Very High (100%)



- | | |
|--------------------------------|---|
| 1. Meyer-McLean Theater | 9. Oregon Trail Building |
| 2. Student Services | 10. Art Building |
| 3. Barber Hall | 11. Albertson Building |
| 4. Weese Building | 12. Maintenance Buildings |
| 5. Vo-Tech Building | 13. Elks Memorial Baseball Field |
| 6. CAD & Drafting Classroom | 14. Dr. John J. Easley Memorial Gymnasium |
| 7. Tech Lab Building | 15. Ore-Ida Sports Complex |
| 8. Workforce Training Building | 16. Malheur Dormitory |
| | 17. Ovyhee Dormitory |
| | 18. Student Life Office |

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1965	1965	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
8549	1	No	No

Plan Irregularities	Vertical Irregularities
Yes: Unknown	Yes: Unknown

Falling Hazards	Poor Conditions
None	
None	
None	