

Adrian SD 61

Building Type	County	
School	Malheur	
Street		
300 High St		
City	State	Zip
Adrian	OR	97901
Latitude		Longitude
43.74226		117.06998
Tracking Code		Inspection Date
RVS in 2006		6/29/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Adrian Elementary School

Final RVS Score


Final Type      Final Score

RM1

-0.1

FEMA-154 Collapse Potential

Very High (100%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
152		1949	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
31672	2	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: L Shaped	Building On Hill or Sloped Site
None	None
None	None

Falling Hazards	Poor Conditions
Parapets: General	None
Other: Brick Veneer	None
Other: Smokestack	None



S Elevation View



S Primary Structural Type



E Elevation View



N Primary Structural Type



E Falling Hazard



N Elevation View