

Building Type	County	
School	Marion	
Street		
4485 Market St Ne		
City	State	Zip
Salem	OR	97301
Latitude		Longitude
44.9509		122.97389
Tracking Code		Inspection Date
Structural Engineering Report		9/15/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	-1	0	0	-0.8	0	-0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Swegle Elementary School

**Final RVS Score**

Final Type	Final Score
W2	-0.5

**FEMA-154 Collapse Potential**

Very High (100%)

No  
Planview  
Available

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
499		1923	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
47610	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions