

Portland CC

Building Type		County	
Community_College		Multnomah	
Street			
12000 Sw 49th Ave			
City		State	Zip
Portland		OR	97219
Latitude		Longitude	
45.43937		122.73154	
Tracking Code		Inspection Date	
Miller 2004-05		8/31/2005	

Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C1	2.5	-1.5	-0.5	0	0	-0.4	0	0	0.1
Secondary	C2	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Tertiary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9

Sylvania - Communication Technology

Final RVS Score

Final Type

Final Score


C1

0.1

FEMA-154 Collapse Potential

High (>10%)

- AM Automotive & Metals
- BK Bookstore
- CC Amo DeBernardia College Center
- CT Communication Technology
- HP Heat Plant
- HT Health Technology
- LRC Library
- PAC Performing Arts Center
- SCB South Classroom Building
- SS Social Science & Technology
- ST Science & Technology
- TCB Technology Classroom Building
- Parking Permit Stations
- ▨ Disabled Parking



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1972	1972	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
80110	2	No	No

Plan Irregularities	Vertical Irregularities
Yes: Unknown	Yes: Unknown

Falling Hazards	Poor Conditions
None	
None	
None	