

Building Type	County	
School	Multnomah	
Street		
15300 Ne Glisan St		
City	State	Zip
Portland	OR	97230
Latitude		Longitude
45.52585		122.50581
Tracking Code		Inspection Date
RVS in 2006		7/17/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary	C2	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Tertiary		0	0	0	0	0	0	0	0	0

Glenfair Elementary School

Final RVS Score

Final Type Final Score

W2

0.9

FEMA-154 Collapse Potential

High (>10%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
525		1954	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
55350	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: 2 to 3 Changes
None	Building On Hill or Sloped Site
None	None

Falling Hazards	Poor Conditions
Unreinforced Chimneys	None
Other: General	None
None	None



N Elevation View



N Plan Irregularity Primary



N Secondary Structural Type



N Falling Hazard



NW Secondary Structural Type



SW Vertical Irregularity Primary



SW Elevation View



SE Elevation View



SE Plan Irregularity Primary



S Secondary Structural Type



SW Falling Hazard



SW Elevation View



SE General Site