

Tillamook Junior High School

Till_sch02A

Tillamook SD 9

Building Type	County	
School	Tillamook	
Street		
3906 Alder Ln		
City	State	Zip
Tillamook	OR	97141
Latitude		Longitude
45.45485		123.82002
Tracking Code		Inspection Date
SER & RVS2006		9/8/2006



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Tertiary		0	0	0	0	0	0	0	0	0

Tillamook Junior High School

Final RVS Score

Final Type Final Score

W2

0.5

FEMA-154 Collapse Potential

High (>10%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
345	1963	1963	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
63043	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: 2 to 3 Changes
None	None
None	None

Falling Hazards	Poor Conditions
Other: Ornamental Hazard Over Exit	None
None	None
None	None



S Building Name



S Vertical Irregularity Primary



S Field Verified Year Built



SE Falling Hazard



E Plan Irregularity Primary



E Other
SOLID CORR WALLS



NE Elevation View



NW Vertical Irregularity Primary



NW Elevation View



SW Vertical Irregularity Primary



SW Secondary Structural Type