

City of Umatilla

Building Type	County	
Police-City	Umatilla	
Street		
300 6th St		
City	State	Zip
Umatilla	OR	97880
Latitude		Longitude
45.91622		119.34835
Tracking Code		Inspection Date
RVS in 2006		8/15/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	0	0	0	-0.8	0	0	4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Umatilla Police Dept

Final RVS Score

Final Type Final Score

W2

4

FEMA-154 Collapse Potential

Low (<1%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
None	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



S Elevation View