

Building Type	County	
Fire - City	Umatilla	
Street		
215 S 3rd		
City	State	Zip
Athena	OR	97813
Latitude		Longitude
45.81061		118.49026
Tracking Code		Inspection Date
RVS in 2006		8/4/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	0	0	0	0	-0.8	0	0	2.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Athena Police Department

Final RVS Score

Final Type Final Score

C2

2.8

FEMA-154 Collapse Potential

Low (<1%)

**No
Planview
Available**

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1952	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
2562	1	No	No

Plan Irregularities	Vertical Irregularities
None	None
None	None
None	None

Falling Hazards	Poor Conditions
Other: General	None
None	None
None	None



N Elevation View



E Elevation View



SW Elevation View



SW Falling Hazard