

Building Type	County	
School	Union	
Street		
1400 Birch St		
City	State	Zip
Elgin	OR	97827
Latitude		Longitude
45.56282		117.92379
Tracking Code		Inspection Date
RVS in 2006		8/4/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	0	-1.2	0	0.1
Secondary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Tertiary		0	0	0	0	0	0	0	0	0

Elgin High School

Final RVS Score

Final Type Final Score

RM1

-0.1

FEMA-154 Collapse Potential

Very High (100%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
139		1957	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
40000	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: 2 to 3 Changes
Reentrant Corners: Other	Steps in Elevation View: Single Change (Adjacent Building/Entity)
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



N Elevation View



NE Elevation View



SW Elevation View



S Elevation View

Elgin High School

Unio_sch14B

Elgin SD 23

Building Type	County	
School	Union	
Street		
1400 Birch St		
City	State	Zip
Elgin	OR	97827
Latitude	Longitude	
45.56286	117.9244	
Tracking Code	Inspection Date	
RVS in 2006	8/4/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Elgin High School

Final RVS Score

Final Type Final Score

RM1

-0.1

FEMA-154 Collapse Potential

Very High (100%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
139		1957	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
40000	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: L Shaped	Steps in Elevation View: Single Change
Reentrant Corners: Other	Steps in Elevation View: Single Change (Adjacent Building/Entity)
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



NW Elevation View



SW Elevation View



S Elevation View