

Mosier Community School

Wasc_sch09A

North Wasco County SD 21

Building Type	County	
School	Wasco	
Street		
1204 1st Ave		
City	State	Zip
Mosier	OR	97040
Latitude		Longitude
45.68294		121.40051
Tracking Code		Inspection Date
RVS in 2006		8/24/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	0	-0.5	-0.4	0	-0.8	0	0	1.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mosier Community School

Final RVS Score

Final Type Final Score

C2

1.9

FEMA-154 Collapse Potential

Moderate (>1%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
128		1920	1920
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
14500	2	Yes	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: Single Change
None	Building On Hill or Sloped Site
None	None

Falling Hazards	Poor Conditions
Unreinforced Chimneys	None
None	None
None	None



S Falling Hazard



SW Plan Irregularity Primary



NW Plan Irregularity Primary



NW Vertical Irregularity Secondary



NW Elevation View



NE Elevation View