

Yamhill FPD

Building Type	County	
Fire - RFPD	Yamhill	
Street		
275 S Olive St		
City	State	Zip
Yamhill	OR	97148
Latitude	Longitude	
45.34019	123.18897	
Tracking Code	Inspection Date	
RVS in 2006	8/21/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	2.4	-0.4	0	0	3.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Yamhill FPD

Final RVS Score

Final Type Final Score

W2

3.3

FEMA-154 Collapse Potential

Low (<1%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1989	1989	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No

Plan Irregularities	Vertical Irregularities
Torsion: Eccentric Stiffness	Internal Discontinuous Diaphragm (large internal opening)
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



S Elevation View



SW Elevation View



W Other



W Other



NW Elevation View



N Building Name



SE Field Verified Year Built
1989



N Number of Stories



NE Primary Structural Type